

November 16, 2011

PAT PATTERSON
COUNTRY VILLAGE MOBILE ESTATES
PO BOX 1749
GRANTS PASS, OR 97528

RE: Notice of Non-Compliance regarding the COUNTRY VILLAGE MOBILE ESTATES Public Water System, PWS OR4100341

Dear PAT PATTERSON,

COUNTRY VILLAGE MOBILE ESTATES is a public water system subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0290.

The Oregon Health Authority, Public Health Division, Office of Environmental Public Health, Drinking Water Program (Program) has reviewed the operation of the COUNTRY VILLAGE MOBILE ESTATES water system and found that it is not being operated in compliance with the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules. Specifically:

- Compliance Deficiency No. 1: OAR 333-061-0036(3)(a) requires sampling for synthetic organic chemicals, but synthetic organic chemical sampling results have not been submitted for the COUNTRY VILLAGE MOBILE ESTATES water system for the most recently completed monitoring period, which constitutes a violation of the rule if samples were in fact not collected.

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

In order for the operation of COUNTRY VILLAGE MOBILE ESTATES water system to return to compliance with OAR 333-061-0036(3)(a), synthetic organic chemical sampling results collected during the current monitoring period must be submitted to the Program no later than January 10, 2012.

COUNTRY VILLAGE MOBILE ESTATES

Page 2

Failure to comply with the deadline specified in this letter may result in additional enforcement action, which could include the assessment of civil penalties as prescribed by OAR 333-061-0090. Please contact JOSEPHINE COUNTY at 541-474-5338 to discuss the compliance actions specified in this letter.

Thank you for your cooperation.

Respectfully,

A handwritten signature in black ink, appearing to read 'BRAD K. DANIELS', with a stylized flourish at the end.

Brad K. Daniels

Enforcement Coordinator

OHA - Drinking Water Program

cc: JOSEPHINE COUNTY
OHA Drinking Water Program Technical Representative