

April 30, 2015

Mark Mezzetta  
Lakeside Mobile Home & RV Park, Inc.  
415 Eastin Dr.  
Sonoma, CA 95476

RE: Notice of Non-Compliance regarding the Lakeside Mobile Home & RV Park  
Public Water System, PWS OR4100450

Mr. Mezzetta:

Our records indicate you own the Lakeside Mobile Home & RV Park, Inc. (Lakeside) water system located at 4850 Wocus Road in Klamath Falls, Oregon. Therefore, you are a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(207), and have specific responsibilities as defined in OAR 333-061-0025.

Lakeside is a community public water system, which serves approximately 100 people, and is subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of Lakeside water system. This review has found that you are not in compliance with the following Oregon administrative rules, and are therefore not meeting your responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

#### DESCRIPTION OF RULE VIOLATIONS

- Violation No. 1: OAR 333-061-0036(7) requires water suppliers to conduct sampling for radionuclides at public water systems. You are required to collect gross alpha samples quarterly at Lakeside water system. However, DWS has not received quarterly gross alpha sampling results for Lakeside water system as required by the rule, which constitutes a violation of OAR 333-061-0036(7) if samples were, in fact, not collected.

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, Lakeside is required to complete the following actions:

- Compliance Action No. 1: Collect samples for gross alpha in accordance with OAR 333-061-0036(7) at the Lakeside water system and report the results to DWS as prescribed by OAR 333-061-0040(1) no later than **July 10, 2015**.

If you do not comply with the deadlines specified in this letter, the continued non-compliance may result in additional enforcement action including the assessment of civil penalties as prescribed by OAR 333-061-0090. Please contact Ramona Quinn at Klamath County Environmental Health at 541-883-1122 ext. 3054 to discuss the compliance actions specified in this letter.

Respectfully,



Janet Brock  
Compliance Specialist  
OHA - Drinking Water Services

cc: Vivian Colahan, Lakeside Mobile Home & RV Park, Inc.  
Betsy Parry, Oregon Health Authority Drinking Water Services  
Ramona Quinn, Klamath County Department of Public Health  
Alan Ray Wells, Lakeside Mobile Home & RV Park, Inc.