

25 November 2015

Michael Persons
Skyview Acres Water Company – PWS 00786
12100 SE Virginia Court
Sandy, OR 97055

Corrective Action Schedule Needed for Skyview Acres Public Water System

Dear Mr. Persons,

This letter is necessary because sample results reported for the Skyview Acres water system exceed the maximum contaminant level (MCL) for haloacetic acids as specified in Oregon Administrative Rule (OAR) 333-061-0030(2)(b). Haloacetic acids are a group of contaminants resulting from the disinfection process when chlorine is added to drinking water.

Owners and operators of public water systems are required to take action to make sure maximum contaminant levels are not exceeded. To comply with this requirement, David Jacob has been piloting a treatment system to reduce the contamination in Skyview Acres drinking water. This treatment system is expected to ensure haloacetic acids do not exceed the MCL once it is permanently installed.

Please submit a corrective action schedule within 90 days of receiving this letter detailing your expectations for ensuring compliance with the MCL for haloacetic acids and including the following information:

1. An expected date for the submission of construction plans to the Oregon Health Authority for the installation of a treatment system; and
2. An expected date for when the treatment system will be operating and effectively removing haloacetic acids from Skyview Acres drinking water.

Please contact me at 971-673-0462 if you have any questions and thank you for your cooperation.

Sincerely,

A handwritten signature in black ink, appearing to read 'Pete Farrelly', written over a horizontal dashed line.

Pete Farrelly, PE
Regional Engineer
Oregon Health Authority
healthoregon.org/dwp

cc: Joel Ferguson, Clackamas County Environmental Health
David Jacob, Skyview Acres Water Company
Drinking Water Program Enforcement Personnel