



Oregon

Theodore R. Kulongoski, Governor

Department of Human Services

Public Health Division

800 NE Oregon Street

Portland, OR 97232-2162

(971) 673-0405

Fax (971) 673-0694

TTY-Nonvoice (971) 673-0372

December 9, 2010

Mike Brown

Saginaw Park public water system

922 Old Town Loop Rd.

Oakland, OR 97462

RE: Notice of Violation for the Saginaw Park public water system, PWS OR4100996

You are a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(211), and have specific responsibilities that are defined in OAR 333-061-0025.

You own and operate Saginaw Park, which is a community public water system serving between 10 and 100 people, and subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0290.

Pursuant to its authority under ORS 448.150, the Oregon Department of Human Services, Office of Environmental Public Health, Drinking Water Program (Agency) has conducted an investigation of the Saginaw Park public water system. This investigation has found that you are not meeting your responsibilities as a water supplier due to the following violations of the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

- Violation No. 1: You failed to take immediate corrective action, as required by OAR 333-061-0025(2), when sample results from the Saginaw Park water system indicated that levels of arsenic exceeded the maximum contaminant level (MCL) as specified in OAR 333-061-0030(1).

You must immediately begin taking corrective action to reduce the concentration of arsenic in the finished drinking water produced by the Saginaw Park water system so that it is below the MCL specified in OAR 333-061-0030(1). You must also notify the Agency of the corrective action to be taken at the Saginaw Park water system, and comply with all applicable requirements specified in OAR 333-061-0005 to 333-061-0290.

Saginaw Park
Page 2

Furthermore, you must immediately contact Katrinka Danielson of the Lane County Environmental Health Department at (541) 682-7462 and notify her of the actions currently being taken to address the exceedance of the MCL for arsenic.

Thank you for your cooperation.

Respectfully,



Brad K. Daniels
Enforcement Coordinator
DHS - Drinking Water Program

cc: Katrinka Danielson at the Lane County Environmental Health Department
Karen Kelley, DHS-DWP
Casey Lyon, DHS DWP

By certified and first class mail