

July 8, 2014

Michael D. Brown
Saginaw Park public water system
922 Old Town Loop Rd.
Oakland, OR 97462

RE: Corrections required for final approval to supply water to customers

On November 28, 2012 you agreed to a Stipulated General Judgment (Judgment) with the State of Oregon related to water quality deficiencies at the Saginaw Park public water system.

Specifically, the Judgment specified that you exercise due diligence to complete construction of an arsenic treatment system and other necessary improvements identified in construction plans for the arsenic treatment system within 120 days of the Authority approving the construction plans.

The construction plans approved by the Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) specifically required additional chemical analyses because components of the proposed treatment system included components that did not meet NSF Standard 61 certification. Specifically, the Authority required additional chemical analyses for inorganic chemicals, volatile organic chemicals and synthetic organic chemicals immediately after startup of the treatment system and again three to six months after startup of the treatment system.

The treatment system was inspected and found to be in use at the Saginaw Park water system on March 19, 2014 but the results from the additional chemical analyses have not been reported to the Authority. You must collect the additional chemical samples and report the analysis results to the Authority before final approval to supply water can be granted. If you do not report the sample results within 30 days of the date of this letter, you will be out of compliance with the terms of the Judgment (paragraph 1.d.) which may result in the additional action taken by the State of Oregon related to the Judgment.

Respectfully,



Brad K. Daniels
Enforcement Coordinator
Oregon Health Authority, Drinking Water Services

cc: Karen Kelley, Oregon Health Authority, Drinking Water Services
Casey Lyon, Oregon Health Authority, Drinking Water Services
Shannon O'Fallon, Oregon Department of Justice
Stephanie Parent, Oregon Department of Justice
Sarah Puls, Lane County Environmental Health