

February 11, 2015

June Hackler  
Dun-Rollin Mobile Home Park, Inc.  
445 E. Jennie Ave  
Hermiston, OR 97838

RE: Notice of Non-Compliance regarding the Dun-Rollin Mobile Home Park Public Water System, PWS OR4101044

Ms. Hackler:

Our records indicate that Dun-Rollin Mobile Home Park, Inc. own and operate the Dun-Rollin Mobile Home Park (Dun-Rollin) water system located at 445 E. Jennie Ave., Hermiston, Oregon. Therefore, Dun-Rollin Mobile Home Park, Inc. is a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(207), and have specific responsibilities as defined in OAR 333-061-0025.

Dun-Rollin is a community public water system, which serves approximately 130 people and is subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of Dun-Rollin water system. This review has found that Dun-Rollin Mobile Home Park, Inc. is not in compliance with the following Oregon Administrative Rules and is, therefore, not meeting its responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

#### DESCRIPTION OF RULE VIOLATIONS

- Violation No. 1: OAR 333-061-0036(2)(c) requires sampling for lead and copper for all community public water systems. DWS notified David Hackler by letter dated August 25, 2014 that lead and copper results had not been reported for the most recent monitoring period, January 1, 2011 to December 31, 2013, which constitutes a violation of the rule if samples were, in fact, not collected.


## ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, Dun-Rollin Mobile Home Park, Inc. is required to complete the following action relating to Dun-Rollin water system:

- Compliance Action No. 1: Collect lead and copper samples in accordance with OAR 333-061-0036(2)(c) and report sample results to DWS no later than **August 15, 2015**.
  - Lead and copper samples must be collected after **June 1, 2015**, which has been determined to be the start of the warmest part of the year. Samples collected before June 1, 2015 will not qualify for compliance or satisfy this compliance action.

If you do not comply with the deadlines specified in this letter, the continued non-compliance may result in additional enforcement action including the assessment of civil penalties as prescribed by OAR 333-061-0090. Please contact Bill Goss or Amy Word of Drinking Water Services at 541-276-8006 to discuss the compliance actions specified in this letter.

Respectfully,



Janet Brock  
Compliance Specialist  
OHA - Drinking Water Services

cc: David Hackler, Registered Agent  
Bill Goss, Amy Word, OHA DWP