



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite #640
Portland, OR 97232-2162
(971) 673-0459
(971) 673-0694 – FAX
<http://healthoregon.org/dwp>

July 5, 2016

Timothy M. Beinert, DPA
Facility Manager/Caretaker
Oregon Military Dept. – Umatilla
Umatilla Chemical Depot
78798 Ordinance Road
Hermiston, OR 97838

**Re: Schedule to Repair Water Tower Deficiencies, Umatilla Army Depot, PWS ID
41 01136**

Dear Mr. Beinert:

The Oregon Health Authority's Drinking Water Services (DWS) has received your June 30th, 2016 written request to complete the repairs at both the Administration and West water towers by November 30th, 2016. DWS has reviewed and approves of the proposed schedule to complete the repairs, accounting for funding and contractor authorization timeframes. The repairs consist of sealing any holes in the towers to ensure that the towers are watertight, as well as ensuring that the hatches in both towers are locked and watertight, to address deficiencies documented in the inspection report prepared by the Depot earlier this year. Provide written documentation (e.g. photos) to me that all repairs are completed.

If you have any questions or concerns, or would like this in an alternate format, please contact me at (971) 673-0459, or james.b.nusrala@state.or.us, or Bill Goss of our Pendleton office at (541) 966-0900, or William.h.goss@state.or.us. Your cooperation is appreciated.

Sincerely,

James Nusrala, P.E.

Regional Engineer

Drinking Water Services

cc: Jon Bloom, Compliance Specialist, Umatilla Chemical Depot, 78798 Ordinance Road, Hermiston, OR 97838

Bill Goss, DWS Pendleton