



Oregon

Theodore R. Kulongoski, Governor

Department of Human Services

Public Health Division

800 NE Oregon Street

Portland, OR 97232-2162

(971) 673-0405

(971) 673-0694 – FAX

(971) 673-0372 - TTY-Nonvoice

March 12, 2010

John Staver
McKee Bridge Mobile Home Park
3030 Upper Applegate Rd
Jacksonville, OR 97530

RE: Amendment to the Notice of Violation for McKee Bridge Mobile Home Park,
Public Water System, PWS OR4101165

Dear Mr. Staver,

You have requested an extension to the compliance deadlines listed in the Notice of Violation originally issued by the Oregon Department of Human Services, Office of Environmental Public Health, Drinking Water Program (Agency) on May 19, 2009. The Notice of Violation requires compliance with the maximum contaminant level (MCL) for arsenic, through either development of a new water source or construction of an arsenic treatment system. The Agency hereby grants your request and amends the Notice of Violation as specified below.

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

In order for McKee Bridge Mobile Home Park to return to compliance with the MCL for arsenic, the following actions must be completed:

- Compliance Action No. 1: McKee Bridge Mobile Home Park must continue to monitor for arsenic every calendar quarter in accordance with OAR 333-061-0036(2)(a) and submit the results of that monitoring not less than 10 days following the end of the quarter (OAR 333-061-0040(1)(b)).

- Compliance Action No. 2: McKee Bridge Mobile Home Park must complete construction and installation of the arsenic treatment system specified in plan review #216-2009 no later than September 30, 2010.
- Compliance Action No. 3: McKee Bridge Mobile Home Park must demonstrate that all system users receive drinking water that consistently meets all applicable state and federal drinking water laws and rules no later than December 31, 2010.
- Compliance Action No. 4: McKee Bridge Mobile Home Park, per OAR 333-061-0042(2)(b), must continue to issue a Tier 2 public notice for exceeding the MCL for arsenic. The public notice must be issued quarterly, until all corrections are made, and all system users receive drinking water that meets all applicable state and federal drinking water laws and rules (OAR 333-061-025 and OAR 333-061-0042(3)(b)(C)). A copy must be submitted to the Agency every calendar quarter, no later than 10 days after completing the public notification per OAR 333-061-0040(1)(i). The notice must be delivered in the manner most appropriate to reach all persons served by the system.

If McKee Bridge Mobile Home Park does not meet the compliance actions and associated deadlines specified in this letter, the continued non-compliance may result in additional enforcement action including the assessment of civil penalties. Please contact Mike Obereigner of Jackson County Environmental Health at (541) 774-7843 to discuss the compliance actions specified in this letter.

Thank you for your cooperation.

Sincerely,



Brad K. Daniels
Enforcement Coordinator
DHS - Drinking Water Program

cc: Scott Curry, DHS DWP
Daniel Hough, DHS DWP
Mike Obereigner, Jackson County Environmental Health