



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services
Kate Brown, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite #640
Portland, OR 97232-2162
(971) 673-0405
(971) 673-0694 – FAX
<http://healthoregon.org/dwp>

January 21, 2016

Bill Palmaymesa
Young Life
PO Box 220
Antelope, OR 97001

Re: Corrosion Control - Young Life, PWS ID #01246

Dear Mr. Palmaymesa:

I am writing in regards to Young Life's plan for corrosion control treatment as required under OAR 333-061-0034 to resolve the 2013 copper action level exceedance in the distribution system.

According to our records, the water system has chosen to pursue alkalinity and calcium hardness adjustment using reverse osmosis for corrosion control treatment. A pilot study plan was reviewed by Drinking Water Services (DWS) on January 12, 2016 to evaluate the effectiveness of this technology. The results from the pilot study will be sent to DWS for review before the full-scale equipment is considered and submitted for plan review approval.

To document the water system's efforts, you must provide DWS in writing **by March 31, 2016** a reasonable timeline to implement corrosion control and serve drinking water that meets the copper action level.

If you have questions please call me at 971-673-0425 or email michelle.p.byrd@state.or.us.

Sincerely,

Michelle Byrd
Drinking Water Specialist

Cc: Brad Daniels, DWS