



**PUBLIC HEALTH DIVISION
Drinking Water Services**

Kate Brown, Governor

**Oregon
Health
Authority**

800 NE Oregon Street, #640

Portland, OR 97232-2162

Phone 971-673-0405

FAX 971-673-0694

TTY-Nonvoice 971-673-0375

9/1/2015

JANET COSGROVE
SOUTH YAMHILL WATER DISTRICT
14613 HWY 47
YAMHILL, OR 97148

RE: Administrative Notice for failure to submit Lead and Copper (LCR) sample results. Must sample before September 30, 2015.

Dear JANET COSGROVE,

This letter is to inform you that LCR sampling results have not been submitted for PWS # OR4101323 during the most recent monitoring period.

5 LCR samples to be collected every 3 years

This is a violation of Oregon Administrative Rule 333-061-0036(2)(c) or OAR 333-061-0040. Furthermore, the Oregon Health Authority, Drinking Water Services (DWS) has not received sample results for these chemicals for the current monitoring period.

LCR samples must be collected during the warmest part of the year, which has been determined to be between June 1 and September 30. Samples collected outside this period do not qualify for compliance.

Also, sampling results must be received by DWS no later than January 10, 2016 (within 10 days of the end of the current monitoring period).

You can submit sampling results to DWS using one of the following methods:

- Fax the report to (971) 673-0694

For faxed data, please include a cover sheet with the number of pages including the cover, your name, and your phone number.

- Email the report to: dwp.dmce@state.or.us
- Mail the report to: Water Quality Reports
P.O. Box 14350
Portland, OR 97293-0350

If the required sampling results are not received, it may result in enforcement action, which could include the assessment of civil penalties.

Please contact Gary VanDerVeen/Shannon Fost/Bonnie Corns with YAMHILL COUNTY at (503) 434-7439 if you have any questions.

Your immediate attention to this matter is appreciated.

Respectfully,

Drinking Water Services