



PUBLIC HEALTH

412 NE Ford Street– McMinnville, OR 97128
Phone: (503) 434-7525 Fax: (503) 472-9731
TTY: 1-800-735-2900 www.co.yamhill.or.us/ph

March 21, 2016

Richard Spon
West Shannon Water System PWS ID# 4105318
16290 Mountain Home Rd
Sherwood, OR 97140

Re: Corrective Action Required to Address Source Water Fecal Contamination at Well L104154 for West Shannon Water System 4105318

Dear Mr. Spon:

The DWS verified that recent monitoring has shown that fecal contamination at your groundwater source. A letter notifying you that resulting corrective action is required was mailed to your attention on January 26, 2015. Oregon Administrative Rule (OAR) 333-061-0076(6) and OAR 333-061-0032(6)(e) requires water systems that use groundwater sources to have completed corrective action or be in compliance with a Department-approved corrective action plan within 120 days of receiving notice of source water fecal contamination.

The West Shannon Water System was to complete corrective action by June 5, 2015 or have a Department-approved corrective action plan with a reasonable timeframe to complete the corrective action. To date, this information has not been received. As a result, the West Shannon Water System is in non-compliance and is now subject to formal enforcement which could include the assessment of civil penalties. In order to return to compliance and avoid formal enforcement action, you must complete corrective action or be on an approved schedule **within 30 DAYS (by April 20, 2016)**. Please send information to:

Gary Van Der Veen/Alisa Zastoupil
Yamhill County Environmental Health
412 NE Ford Street
McMinnville, OR 97128

A copy of the letter is enclosed for your reference.

Since West Shannon Water System failed to take action within the required timeframe, you **must provide notification** to all persons served by the water system as soon as practical and by no later than 30 days after the date of this letter. The public notice must include the mandatory language and corrective action taken. You are also required to issue a repeat notice every three months until all deficiencies are corrected or you are in compliance with an approved corrective action plan. A copy of the Tier 2 public notice instructions and template are enclosed.

A copy of the public notice must be sent to the Oregon Health Authority – Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 within ten (10) days after completion to certify that the West Shannon Water System has fully complied with the distribution and public notification requirements.

Please contact Gary Van Der Veen at 503-434-7439 or me at 503-583-0361 by phone (Mondays only) or via email at zastoupila@co.yamhill.or.us if you have questions or comments.

I appreciate your immediate attention to this matter.

Sincerely,



Alisa Zastoupil, REHS
Yamhill County Environmental Health

cc: Gary Van Der Veen, Yamhill County Environmental health
Evan Hofeld, Regional Engineer, Drinking Water Services
Tom Pattee, R.G. Groundwater Coordinator

Enclosures: Tier 2 public notice template 2-21 and instructions
Corrective Action letter to Address Source Water Fecal Contamination