



PUBLIC HEALTH DIVISION
Drinking Water Services

John A. Kitzhaber, MD, Governor

Oregon
Health
Authority

800 SE Emigrant Avenue, Suite 240
Pendleton, OR 97801
Phone: 541-276-8006
Fax: 541-276-4778
<http://healthoregon.org/dwp>

June 9, 2014

Walt Longtin
River Village Mobile Home Park
3605 SW 4th Avenue
Ontario, Oregon 97914

RE: Compliance Schedule for Violations at River Village MHP public water system

Dear Walt:

This letter is a follow-up to our conversation regarding establishing a timeframe for correction of the violation specified below at the **River Village Mobile Home Park, PWS ID #4105854**. As we discussed, when a public water system has unresolved violations for more than 5 months, these violations must then be resolved within 90 days or be on an approved timeline for correction; otherwise the water system will be referred for formal enforcement.

The River Village Mobile Home Park water system has the following violation that must be resolved within 90 days or be on an approved timeline for correction:

Violation: Exceeding the Maximum Contaminant Level (MCL) for arsenic.

As we discussed, your plan is to drill a new test well and collect water quality samples from it. If the water samples from the test well meet quality standards, a new drinking water supply well will be completed. Otherwise, a treatment system will need to be added to the existing well. Please provide proposed completion dates for the following actions by July 9, 2014:

1. Drill a test well.
2. Collect water quality samples from the test well.
3. Drill a water supply well (provided the water quality results from the test well are acceptable).
4. Connect the new water supply well to the potable water system.



Walt Longtin
June 9, 2014
Page 2 of 2

Failure to provide proposed dates for the above compliance schedule may result in formal enforcement action which could include the assessment of civil penalties. If you have any questions or concerns, please call me at (541) 966-0900. Thank you for your cooperation.

Sincerely,

A handwritten signature in cursive script that reads "William Goss" followed by a long horizontal flourish.

William Goss
Regional Engineer

cc: Brad Daniels, OHA Drinking Water Services