

PUBLIC HEALTH DIVISION
Office of Environmental Public Health, Drinking Water Program
John A. Kitzhaber, MD, Governor

Oregon
Health
Authority

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

November 16, 2011

FRANK BROWN
SHADY POINT SDA CHURCH
5344 S FORK LITTLE BUTTE CREEK RD
EAGLE POINT, OR 97524

RE: Notice of Non-Compliance regarding the SHADY POINT SDA CHURCH Public Water System, PWS OR4191501

Dear FRANK BROWN,

SHADY POINT SDA CHURCH is a public water system subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0290.

The Oregon Health Authority, Public Health Division, Office of Environmental Public Health, Drinking Water Program (Program) has reviewed the operation of the SHADY POINT SDA CHURCH water system and found that it is not being operated in compliance with the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules. Specifically:

- Compliance Deficiency No. 1: OAR 333-061-0036(2)(d) requires sampling for nitrate at all public water systems, but nitrate sampling results have not been submitted for the SHADY POINT SDA CHURCH water system for the 2010 annual monitoring period, which constitutes a violation of the rule if samples were in fact not collected.

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

In order for the operation of SHADY POINT SDA CHURCH water system to return to compliance with OAR 333-061-0036(2)(d), nitrate sampling results collected during the current monitoring period must be submitted to the Program no later than January 10, 2012.

Failure to comply with the deadline specified in this letter may result in additional enforcement action, which could include the assessment of civil penalties as prescribed by OAR 333-061-0090. Please contact JACKSON COUNTY at 541-774-7843 to discuss the compliance actions specified in this letter.

Thank you for your cooperation.

Respectfully,



Brad K. Daniels
Enforcement Coordinator
OHA - Drinking Water Program

cc: JACKSON COUNTY
OHA Drinking Water Program Technical Representative