

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

BEFORE THE STATE OF OREGON
OREGON HEALTH AUTHORITY
CENTER FOR HEALTH PROTECTION

In the Matter of

Kevin Cameron / Glenwood's Own
Braap Shop, Deli & Park, LLC Public
Water System

BILATERAL COMPLIANCE AGREEMENT

Kevin Cameron owns and operates the Glenwood's Own Braap Shop, Deli & Park, LLC (Glenwood) public water system, identified by public water system ID # OR4191611 and located at 57975 NW Wilson River Hwy. in Gales Creek, Oregon. The Glenwood water system is a transient non-community water system serving approximately 100 people and subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.

Kevin Cameron is therefore a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(207), and as a water supplier, has specific responsibilities that are identified in OAR 333-061-0025.

Pursuant to its authority under ORS 448.150, the Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) has reviewed the operation of the Glenwood water system. The Authority has determined that the Glenwood water system is utilizing a spring collection box that is contaminated with *E. coli* bacteria and does not meet construction standards as a water source for public drinking water. This represents a potential public health hazard.

This agreement is entered into between the Authority and Kevin Cameron to establish a commitment to replace the spring supplying drinking water to the Glenwood water system with a groundwater well that meets all applicable construction standards and has been granted final approval as a water source by the Authority.

FINDINGS OF FACT

- Water samples collected on October 24, 2014 confirmed the spring supplying water to the Glenwood water system is contaminated with *E. coli* bacteria.
- OAR 333-061-0032(6) requires corrective action when a groundwater source is confirmed to be contaminated with *E. coli* bacteria. OAR 333-061-0050(5)(b) requires that groundwater sources with a history of microbiological contamination be upgraded to meet current construction standards before disinfection treatment may be permanently installed.
 - Therefore the spring supplying water to the Glenwood water system must be repaired so that it meets the applicable construction standards for spring collection boxes or it must be disconnected from the Glenwood water system and replaced with a new water source.
- Kevin Cameron complied with a directive from the Oregon Department of Agriculture to provide disinfection treatment at the Glenwood water system as an interim measure to protect public health until the *E. coli* contamination in the source water is resolved.
- Kevin Cameron notified the Authority on December 29, 2015 that he intends to replace the spring supplying drinking water to the Glenwood water system by submitting plans and a plan review fee for a proposed groundwater well.
- Kevin Cameron failed to ensure the proposed groundwater well was completed by February 1, 2016 as required in directive from the Oregon Department of Agriculture.

AGREEMENT

Upon completion of the activities described below, by the deadlines specified herein, Kevin Cameron will have satisfied the terms of this agreement and will be considered to be in compliance with the rule(s) mentioned hereto.

- Agreement Activity No. 1: Kevin Cameron agrees to submit to the Authority a land use compatibility statement for a proposed drinking water well to serve the Glenwood water system signed by the Washington County Planning Department.
 - The land use compatibility statement will be submitted no later than April 30, 2016.
- Agreement Activity No. 2: Kevin Cameron agrees to ensure construction of the groundwater water well identified by Authority plan review number 204-2015 is completed no later than June 30, 2016.
 - The well must meet all applicable construction standards specified in OAR 333-061-0050 such that the Authority can grant final approval for the well construction project within 30 days of construction being completed.
- Agreement Activity No. 3: Kevin Cameron will submit the results from a water sample analyzed for total coliform bacteria and *E. coli* bacteria collected at the well specified in Agreement Activity No. 2 at the Glenwood water system.
 - The sample results will be reported to Authority within 30 days of completing construction according to Agreement Activity No. 2.
 - Samples will be collected according to the applicable standards specified in OAR 333-061-0036.
- Agreement Activity No. 4: Kevin Cameron will ensure the existing spring is physically and completely disconnected from the Glenwood water system within 30 days of completing construction according to Agreement Activity No. 2.
 - The point of disconnection must be made available for inspection by personnel from the Authority or the Oregon Department of Agriculture before waterlines are buried following excavation or construction.


GENERAL PROVISIONS

This Agreement does not constitute a waiver, suspension or modification of the requirements of the Oregon Drinking Water Quality Act; ORS 448.115 to 448.285 and administrative rules OAR 333-061-0005 to 333-061-0272, which remain in full force and effect.

This Agreement does not relieve Kevin Cameron of any responsibilities or liabilities established pursuant to any applicable federal, state, or local law or regulation.


The Authority has determined that additional enforcement action is not warranted at this time, and so long as Kevin Cameron meets all of the requirements and deadlines specified in this Agreement, the Authority will forgo additional enforcement action which could include the assessment of civil penalties as prescribed by OAR 333-061-0090.

Dated this 9th day of March, 2016.



Kevin Cameron
Owner
Glenwood's Own Braap Shop, Deli & Park, LLC

Dated this 9th day of March, 2016.



Dave Leland, PE
Program Manager
Oregon Health Authority, Drinking Water Services

cc: James Nusrala, Oregon Health Authority, Drinking Water Services
Steven Wong, Oregon Department of Agriculture