

Linn County Department of Health Services

P.O. Box 100, Albany, OR 97321 Toll Free: 800-304-7468 TTY /Oregon: 800-735-2900

www.co.linn.or.us/health

"Working together to promote the health and well-being of all Linn County residents."

March 30, 2016

Brian Carroll Linn County Parks 3010 Ferry St. SW Albany, OR 97321

RE: Compliance Schedule for Violations at the USFS House Rock CG HP 1 public water system

Dear Mr. Carroll,

This letter is a follow-up to our conversation(s) regarding the timeframe for correction of the violations specified below at USFS House Rock CG HP 1. As we discussed, when a public water system has unresolved violations for more than 5 months, these violations must then be resolved within 90 days or the water system will be referred for formal enforcement.

The presence of coliform bacteria in August and September of 2015 constitutes an exceedance of the maximum contaminant level for coliform bacteria, which is specified in Oregon Administrative Rule (OAR) 333-061-0030(4). Owners and operators of public water systems are required to take action to make sure maximum contaminant levels are not exceeded. Your water system must correct this violation within 90 days.

You stated the plan was to shock the system sometime in April and then take a special sample to verify it worked. If there is no presence of coliform bacteria you would then open for the season. Failure to comply with the above compliance schedule may result in formal enforcement action which could include the assessment of civil penalties. If you have any questions or concerns, please call me at (541) 967-3821 ext. 2098.

Thank you for your cooperation.

Sincerely,

Alyson Reynolds, REHS

Linn County Environmental Health Program

Alyson Keynolds

cc:

Drinking Water Services Enforcement

Oregon Health Authority, Drinking Water Services