



Oregon

Theodore R. Kulongoski, Governor

Department of Human Services

Public Health Division

800 NE Oregon Street

Portland, OR 97232-2162

(971) 673-0405

Fax (971) 673-0694

TTY-Nonvoice (971) 673-0372

November 23, 2010

Daniel and Glenna Thorsland
Sleepy Hollow RV Park
19316 Hwy 42
Myrtle Point, OR 97458

RE: Notice of Violation for the Sleepy Hollow RV Park public water system, PWS
OR4194283

Mr. and Mrs. Thorsland,

Sleepy Hollow RV Park is a transient non-community public water system serving between 10 and 100 people, subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0290.

As the owners of Sleepy Hollow RV Park, you are considered water suppliers as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(211), and have specific responsibilities that are defined in OAR 333-061-0025.

OAR 333-061-0025(2) requires all water suppliers to take immediate corrective action when the results of analyses or measurements indicate that maximum contaminant levels have been exceeded.


- Violation No. 1: The Turbidity Monitoring Report Forms submitted for Sleepy Hollow RV Park indicate that less than 95% of the turbidity measurements recorded for both the September and October 2010 monitoring periods were less than or equal to 0.3 NTU, which is considered an exceedance of the maximum contaminant level (MCL) for turbidity as specified in OAR 333-061-0030(3)(b)(A)(i). The Drinking Water Program has not received notification that you have taken corrective action, which is considered a violation of OAR 333-061-0025(2).

- Compliance Action No. 1: You must take action to ensure that filtered water turbidity does not exceed the MCL as specified in OAR 333-061-0030(3)(b)(A)(i) or (ii), and be able to demonstrate compliance with the MCL no later than April 30, 2011. Failure to take action to correct the exceedance of the MCL for turbidity may result in additional enforcement action, which could include the assessment of civil penalties.

Please contact Jay MacPherson at the Drinking Water Program at (541) 726-2587 - extension 57, to discuss the requirements specified in this letter.

Thank you for your cooperation.

Respectfully,



Brad K. Daniels
Enforcement Coordinator
DHS - Drinking Water Program

cc: Rick Hallmark, Coos County Environmental Health
Eric Hinman, Sleepy Hollow RV Park
Jay MacPherson, DHS DWP