

**BEAR CREEK MOBILE HOME PARK LLC**

Cross Connection Enabling Ordinance

**Water System Name:** Bear Creek Mobile Home Park

**Water System PWS ID#:** 4100050

**Date of Water System approval of this document:** 02/14/13

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with OAR 33-061-0070 thru 333-061-0074.

This includes installation, maintenance and testing of backflow prevention devices and assemblies; as well as other rules to report backflow data to the Oregon Health Authority every year.

Actual or potential cross connections are prohibited. If a potential exists for a cross connection and this is necessary, the water system must be protected by an appropriate backflow prevention device or assembly. Most high hazards or health hazard are specified in the above listed Oregon Administrative Rules. They should be given the highest priority by this water system.

BCMHP LLC has the right to refuse or terminate water service to any customer who does not install a backflow device or assembly, when necessary, test at least annually and repair if necessary the backflow devices on the customer's property.

BCMHP LLC reserves the right to demand a backflow device at the customer's side of the water meter if access is not allowed to determine if a backflow device or assembly is necessary.

BCMHP LLC will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.

Mike Skinner 2/14/13  
Mike Skinner

BEAR CREEK MOBILE HOME PARK  
CROSS CONNECTION CONTROL PROGRAM PLAN

The purpose of the (ordinance/policy) is to protect the water supply of Bear Creek Mobile Home Park (BCMHP) from contamination or pollution from any cross connections; and to assure that approved backflow prevention assemblies are tested when put into service and at least on an annual basis thereafter. This ordinance is in compliance with Oregon Administrative Rule (OAR) 333-061-0071 and the Uniform Plumbing Code (UPC) as adopted by the State of Oregon.

The installation or maintenance of any unprotected cross connection which would endanger the water supply of (BCMHP) is prohibited. Any such cross connection now existing or hereafter installed is hereby declared unlawful and shall be immediately protected or eliminated.

The control or elimination of cross connection and the criteria from determining degrees of hazard and prescribing appropriate levels of protection shall be in accordance with the UPC and or OAR's.

Water service to any premise shall be contingent upon the customer providing appropriate cross connection control if determined necessary. Determinations and enforcement shall be the responsibility of (BCMHP) in conjunction with county plumbing inspector. Water service may be refused or terminated to any premises where an unprotected cross connection may allow contamination or pollutants to backflow into the public drinking water system.

Authorized employees of (BCMHP) with proper identification, shall have free access at reasonable hours of the day, to all areas of a premise or building to which drinking water is supplied for the purpose of conducting hazard assessment surveys.

Water service may be refused or terminated, or maximum backflow protection may be required, to the premise where access to perform surveys is denied, where unprotected cross connections are located, or in the event that installed assemblies are not tested and maintained as required by State and local regulations.

Before any water service is terminated, a "due process" of notifying the customer and providing a reasonable time for compliance to be achieved will be observed according to the operating procedures of (BCMHP). However, in the event of an actual backflow incident which endangers the public health, water service may be terminated immediately and not be restored until the cross connection is either eliminated or adequately protected.

\*\*\*\*\*

Signature Mike Stein Date 2-14-13