

December 8, 2014

David Shaff, Administrator  
Portland Water Bureau  
1120 SW 5<sup>th</sup> Avenue  
Room 600  
Portland, OR 97204-1926

Re: **Tabor Reservoir Adjustments (PR#190-2014)**  
**Portland Water Bureau (PWS ID#00657)**  
**Conditional Approval**

Dear David:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Tabor Reservoir Adjustments for Portland Water Bureau. On October 31, 2014, our office received a set of plans and a review fee of \$600.

The project includes adjustments on Mt. Tabor as well as piping changes on SE Lincoln and SE 60<sup>th</sup> Streets. I note that with this project, the Bureau intends to complete the physical disconnections by December 31, 2015.

The plans are approved with the following conditions:

- Disinfection of the new waterline should be completed according to AWWA C651.
- Any water line and sewer line/lateral crossings must conform to OAR 333-061-0050 (9)(c). Please contact me if field conditions of water line/sewer line parallel alignments are found to be in zones 2 through 4 as indicated in OAR 333-061-0050(9)(b).
- All items in contact with potable water must meet NSF 61 or equivalent.

Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #190-2014 and can be emailed to me

at Carrie.L.Gentry@state.or.us or mailed to:

Attn: Carrie Gentry  
OHA-Oregon Drinking Water Services  
PO Box 14450  
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 673-0191.

Sincerely,

A handwritten signature in black ink, appearing to read 'C. Gentry', with a stylized flourish at the end.

Carrie Gentry, PE  
Regional Engineer  
Drinking Water Services